

Inspection Record for Cable Trays/Ladders

Record No.: _____

Client: _____	Subcontractor: _____
Project No.: _____	Subcontract P.O. No.: _____
Project Name: _____	Designation of trays/ladders: _____

<u>Additional Information:</u>	Vendor: _____
Reference Document: _____	P.O. No.: _____

Items to inspect	Subcontractor	Company		Remarks
	inspected initials/date	Hold Point	inspected* initials/date	
1.0 Specified material used		h		
2.0 Location, routing, spacing, width				
3.0 Vertical runs plumb and parallel				
4.0 Cut edges painted				
5.0 Assembly correctly bolted up				
6.0 Supports, hot-dip galvanized				
7.0 Covers on HV cable trays				
8.0 Tray and ladder runs adequately supported				
9.0 Trays, ladders and supports bonded and earthed				
10.0 "As built" information recorded on drawing no.				

H - Company's presence is mandatory for all activities in section.

h - Company's presence is mandatory.

Attachments, No. of pages: _____

Accepted for Subcontractor	Accepted for Company	Accepted for Client
Name: _____	Name: _____	Name: _____
Signature: _____	Signature: _____	Signature: _____
Date: _____	Date: _____	Date: _____

*Company only initials for holdpoint