

Inspection Record for Local Indicating Instruments Press., Temp., Flow and Level Gauges

Record No.: _____

Client: _____

Subcontractor: _____

Project No.: _____

Subcontract P.O. No.: _____

Project Name: _____

Plant/Area/Unit Nos.: _____

Reference Document:

| Tag No. | Location | Accepted Initial/Date | Tag No. | Location | Accepted Initial/Date |
|---------|----------|--------------------------|---------|----------|--------------------------|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

1. Check correct instrument is installed at correct P.I.D. location
2. Check integrity of process installation (no open plugs etc.)
3. Verify all instruments have been check calibrated (certificates available, stickers on instruments)
4. Check accessibility
5. Check correct gasket materials installed

Remarks:

| Accepted for Subcontractor | Accepted for Company | Accepted for Client |
|----------------------------|----------------------|---------------------|
| Name: _____ | Name: _____ | Name: _____ |
| Signature: _____ | Signature: _____ | Signature: _____ |
| Date: _____ | Date: _____ | Date: _____ |